



INSTRUCTIONS PERTAINING TO RISK OF FIRE OR INJURY TO PERSONS. READ ALL INSTRUCTIONS. IMPORTANT SAFETY INSTRUCTIONS. SAVE THESE INSTRUCTIONS.

DANGER - RISK OF SHOCK - DISCONNECT POWER BEFORE INSTALLATION! Please read all instructions before installation.

- Keep these instructions for future reference.
- Must be installed by a qualified electrician in accordance with national and local standards. Designplan is not responsible for fixtures installed without regard to these standards.
- Unauthorized alterations or tampering of product voids warranty.
- The main power connection must be in accordance with local electrical codes.
- Suitable for OUTDOOR or INDOOR applications.
- For INDOOR installations: DO NOT INSTALL INSULATION WITHIN 3.0" (76 mm) OF ANY PART OF THE LUMINAIRE.



IP67 IK10

Electrical Connections:

- LED lights must be **connected in parallel** respecting polarities.
- **CHOOSE POWER SUPPLY ACCORDINGLY.** Please consider the voltage through which fixtures are fed as well as the max power consumption.
- **Connect power only if all the fixtures are connected.**
- The power supplies **MUST** be installed in aerated rooms, far from heat sources. Overworking or lack of air circulation will not permit natural dissipation.
- Use only Class 2 type electronic power supply.
- Never use switches on secondary circuit.

ATTENTION: **For Wall/Ceiling** - It is the contractor's responsibility to caulk around all the edges between the fixture and the mounting surface to satisfy wet label requirements.

For In-Grade - It is the contractor's responsibility to seal the conduit with "Great Stuff" aerosol seal that prevents water and moisture penetration for ultimate protection.

Contractor **MUST** use gel-filled wire nuts.

Maintenance

Scheduled maintenance must be carried out once a year on all lighting devices, regardless of appliance class and type of use. It must include the following operations:


- Periodically clean fixtures to remove dirt from gratings and screw heads.
- Check tightness of screws on various parts of the device.
- Check that all cable glands and cables are intact and tight. Check that the glass or plastic lens is intact, and replace it if broken or damaged.
- The internal components such as the ballast, driver, washers and screws must not show clear signs of oxidation or rust. Clear traces of rust and oxidation will indicate the presence of water inside the device.
- In the case of damage, the components must be replaced by original components or spare parts.

LINE STRONG 1 / 2

Remote 24VDC, 5.4W (Line Strong 1), 10.8W (Line Strong 2)

installation instructions

TECHNICAL DRAWING




LINE STRONG*

model	code	size	lamp	lumens		
				2700K	3000K	4000K
LINE STRONG 1	06.104122	20.28"x1.18"xH1.81"	LED 5.4W	756	840	924
LINE STRONG 2	06.104123	39.96"x1.18"xH1.81"	LED 10.8 W	1512	1680	1848








ACCESSORIES






code		code	
	20.101250 LINE STRONG 1 Case sizes L20.28" x 2.81" x 1.36" H2.76"		20.101086 LINE STRONG 1 Lower closing end cap for concrete
	20.101251 LINE STRONG 2 Case sizes L39.96" x 2.81" x 1.36" H2.76"		20.101087 LINE STRONG 2 Lower closing end cap for concrete
	20.101069 Couple of closing end caps		20.104464** lighting source extraction tool kit
	20.101068 Couple of joints for continuous line		



INGROUND SINGLE PRODUCT INSTALLATION







INGROUND CONTINUOUS LINE INSTALLATION





LINE STRONG 1 / 2

Remote 24VDC, 5.4W (Line Strong 1), 10.8W (Line Strong 2)

installation instructions







20.101086 - 20.101087 - 20.101088



LINE STRONG 1 / 2


Remote 24VDC, 5.4W (Line Strong 1), 10.8W (Line Strong 2)

installation instructions



**It is the installers responsibility to ensure the wire connection has a water tight seal (IP68)

Wiring Diagram



The individual lamps must be connected in parallel. Only power up the system once all the lamps have being connected.

- Only power up the system once all the lamps are connected. Connecting an individual lamp to an active power supply may cause the lamp to break due to over-voltage.
- Lamps and power supply units must be installed in well-ventilated boxes or locations to allow a natural heat diffusion and avoid the devices overheating.
- On the power system, install a surge protection device to reduce the intensity of any voltage spikes to protect the lighting fixtures from the risk of damage.
- Fixture NOT suitable for covering with thermally insulating material.