



## Installation instructions for PARAPIT

### FAILURE TO FOLLOW THESE INSTRUCTIONS WILL VOID WARRANTY

RISK OF ELECTRICAL SHOCK. THIS EQUIPMENT IS TO BE INSTALLED BY A QUALIFIED ELECTRICIAN ONLY. MAKE CERTAIN ELECTRICAL SUPPLY CIRCUIT IS DE-ENERGIZED BEFORE BEGINNING INSTALLATION. CHECK FIXTURE LABEL FOR CORRECT VOLTAGE. READ ALL INSTRUCTIONS CAREFULLY.

### INSTALLATION

1. The lighting fixture comes fully assembled.
2. Remove grill, lens and tray and connect the body to a standard outlet box. Designplan recommends that the contractor utilize the three mounting holes in the back of the body to mount to the structure as well. It is the contractor's responsibility to supply proper anchorage based on job conditions. It is also the contractor's responsibility to caulk the back of the fixture in order to satisfy wet label requirements.
3. Unplug the amp connector. Make supply lead connections in the body using the female amp connector. CONNECT GREEN WIRE TO "GROUND", CONNECT BLACK FIXTURE TO BLACK BUILDING WIRE AND CONNECT WHITE FIXTURE WIRE TO WHITE BUILDING WIRE. Plug amp connector back together.
4. Secure the ballast tray inside the body.
5. Install lamp.
6. Affix the grill and lens over the housing.

2D lamps must not be inverted as shown in the diagram in order to avoid overheating the end of the cap marked C.

